| TRACKING# 69313 ST | STATE OF TEXAS WELL REPORT Date Entered: 10/23/2005 | | | | | | |
|--|--|--|--|--|--|--|--|
| OWNER: WEST BRAZOS W.S.C. | OWNER 7025 SANGER AVE | | | | | | |
| ADDRESS OF WELL'S LOCATION: | ADDRESS: WACO, TX 76740 | | | | | | |
| COUNTY: McLennan LATITUDE: 312522 Owner's Well Number: 2 | LONGITUDE: 970347 Brand/Model of GPS: LORANCE AIRMA ELEVATION: 392 Grid Number: 40 - 40 - 517 | | | | | | |
| TYPE OF WORK: ✓ New Well | | | | | | | |
| WELL LOG: DIAMETER OF HO Date Drilling Dia. (in) From (ft.) Started 9/26/2004 22 Surface Completed 10/1/2005 14.750 35 | • | | | | | | |
| BOREHOLE COMPLETION: ☐ Open Hole ☐ Underreamed ☐ Other ✓ Straight Wall ☐ Gravel Packed | From 6 ft. to 2712 ft. #Sacks + Material 1100 CEMENT From ft. to ft. #Sacks + Material From ft. to ft. #Sacks + Material Method Used HALLIBURTON METHOD | | | | | | |
| Gravel Packed Interval from ft. to | ft. Cemented By JET STAR CEMENTE | | | | | | |
| SURFACE COMPLETION: | Distance to Septic System N/A Distance to Property Line: 150 | | | | | | |

| TIPE OF FUNIF: | | | | | | |
|--|-------------------|--------------------------------------|-------|--|--|---|
| ☐ Turbine ☐ Jet ☑ Submersible ☐ Cylinder | | | | | | |
| Other | | | | | | |
| Depth to pump bowls, cylinder, jet, etc. 853 | 1 PACKER | S: | | | | |
| WELL TESTS: | Type | | Depth | | | |
| Type of test: ✓ Pump ☐ Bailer ☐ Jetted ☐ Est | imated NONE | NONE | | | | |
| Yield: 305 gpm with 74 ft. drawdown after 36 | hrs. | , | | | | |
| WATER QUALITY: | | ater: N/A | | | | • |
| Did Driller knowingly penetrate any strata which contained undesirable constituents? | Yes No Depth of S | | | | | |
| | | Chemical Analysis made? ✓ Yes No | | | | |
| | | | | | | |

TX 76126

Date 12/15/2004

FT. WORTH

PLUGGING INFO:

Casing left in well: From (ft.) To (ft.

☐ Well Plugged within 48 hours

WELL DRILLER'S LICENSE NO.

Cement/Bentonite left in well:

From (ft.) To (ft.) Cem/Bent Sacks Used:

2457

Name as Signature TIM WATTS Registered Driller Apprentice

Driller Comments

ft. below land surface

gpm.

COMPANY NAME: WATTS DRILLING CO.

ADDRESS 14310 HWY 377 S

WATER LEVEL:

Static Level 580

Artesian Flow

WELL REPORT CONFIDENTIALITY NOTICE

TEX. OCC. CODE Title 12, Chapter 1901.251, authorizes the owner (owner or the person for whom the well was drilled) to keep information in Well Reports confidential. The Department shall hold the contents of the well log confidential and not a matter of public record if it receives, by certified mail, a written request to do so from the owner. Please include the report's Tracking number on your written request.

Texas Department of Licensing Regulation Water Well Driller/Pump Installer Section P.O. Box 12157 Austin, TX 78711 Toll free (800)803-9202 (512)463-7880 FAX (512)463-8616

Email address: water.well@license.state.tx.us Web address: www.license.state.tx.us

DESCRIPTION AND COLOR OF FORMATION MATERIAL CASING, BLANK PIPE, AND WELL SCREEN DATA From (ft.) To (ft.) Description Dia. New/Used Type Setting From/To Gage 000 - 025 BROWN CLAY 16 NEW STEEL 0/35 025 - 035 SANDY BROWN CLAY J-55 STC 40.5 LBS 2'+/2710 10 3/4 NEW 035 - 1185 GRAY SHALE AND LIME STREAKS PERFORATED 2508/2520 1185 - 1473 GRAY SHALE PERFORATED 2526/2568 1473 - 1800 LIME AND GRAY SHALE PERFORATED 2618/2631 1800 - 2030 LIME 2030 - 2100 SAND PERFORATED 2643/2656 2100 - 2150 LIME PERFORATED 2666/2676 2150 - 2270 LIME AND SAND STREAKS TOTAL 180 PERFORATIONS 2270 - 2570 SAND 2570 - 2650 LIME AND SAND STREAKS 2650 - 2680 SAND

2680 - 2710 YELLOW SHALE