

Send original copy by certified mail to the Texas Department of Water Resources P. O. Box 13067 Austin, Texas 78711

State Texas
WATER WELL REPORT

For TDWR use only
Well No. 40-30-AD
Located on map WACO
Received: _____

ATTENTION OWNER: Confidentiality Privilege Notice on Reverse Side

1) OWNER WISLACK WATERWORKS 73205 Address 8266 Wille (City) TX (State) (Zip)
2) LOCATION OF WELL: County MCGRAW 7 miles in NE direction from WACO (Town) Speargrillie (N.E., S.W., etc.) (Town)

Legal description: Section No. _____ Block No. _____ Township _____
Abstract No. _____ Survey Name _____
Distance and direction from two intersecting section or survey lines _____
 See attached map. 40-30-AD

3) TYPE OF WORK (Check):
 New Well Deepening Reconditioning Plugging
4) PROPOSED USE (Check):
 Domestic Industrial Public Supply Irrigation Test Well Other
5) DRILLING METHOD (Check):
 Mud Rotary Air Hammer Driven Bored Air Rotary Cable Tool Jetted Other

6) WELL LOG:

Date drilled	DIAMETER OF HOLE		
	Dia. (in.)	From (ft.)	To (ft.)
<u>11-5-11/19/84</u>	<u>12 1/4</u>	Surface	<u>25</u>
	<u>9 7/8</u>	<u>26</u>	<u>113 1/2</u>

7) BOREHOLE COMPLETION:
 Open Hole Straight Well Underreamed
 Gravel Packed Other
If Gravel Packed give interval ... from _____ ft. to _____ ft.

From (ft.)	To (ft.)	Description and color of formation material	8) CASING, BLANK PIPE, AND WELL SCREEN DATA:		Setting (ft.)		Gage Casing Screen
			Dis. (in.)	New or Used	Steel, Plastic, etc. Perf., Slotted, etc. Screen Mgt., if commercial	From	
0	23	GRAVEL & CLAY					
24	475	BLACK SAND & CLAY	10 1/4	N	STEEL	0	25
476	583	PAVING					
584	1066	GRAN. RES. CLAY	7	N	STEEL	0	1130
1067	1125	1ST TRINITY	7	N	PUR-FORMED	1066	1130
1126	1135	BLACK SAND					

CEMENTING DATA
Cemented from 0 ft. to 1064 ft.
Method used PRESSURE
Cemented by MEADOWS (Company or Individual)

9) WATER LEVEL:
Static level 105 ft. below land surface Date 1/19/84
Artesian flow _____ gpm. Date _____

10) PACKERS: Type _____ Depth _____

RECEIVED
FEB-6 1984

DEPT. OF WATER RESOURCES
(Use reverse side if necessary)

13) WATER QUALITY:
Did you knowingly penetrate any strata which contained undesirable water? Yes No
If yes, submit "REPORT OF UNDESIRABLE WATER"
Type of water? _____ Depth of strata _____
Was a chemical analysis made? Yes No

11) TYPE PUMP:
 Turbine Jet Submersible Cylinder
 Other _____
Depth to pump bowls, cylinder, jet, etc., _____ ft.

12) WELL TESTS:
 Type Test Pump Boiler Jetted Estimated
Yield: 15 gpm with 20 ft. drawdown after 1 hrs.

I hereby certify that this well was drilled by me (or under my supervision) and that each and all of the statements herein are true to the best of my knowledge and belief.

NAME Ray Meadows (Type or Print) Water Well Drillers Registration No. 1444
ADDRESS 6611 Sander (Street or RFD) WACO (City) TX (State) 76710 (Zip)
(Signed) [Signature] (Water Well Driller) MEADOWS MILL, INC (Company Name)

Please attach electric log, chemical analysis, and other pertinent information, if available.