


Original copy by  
 Filed mail to the  
 Water Development Board  
 Box 12386  
 Austin, Texas 78711

State of Texas  
 WATER WELL REPORT

For TWDB use only  
 Well No. \_\_\_\_\_  
 Located on map \_\_\_\_\_  
 Received: \_\_\_\_\_

OWNER: Elm Creek Water Supply Corp Address Moody Texas  
 (Name) (Street or RFD) (City) (State)  
 Owner: Elm Creek Water Supply Corp Address Moody Texas  
 (Name) (Street or RFD) (City) (State)

LOCATION OF WELL:  
 County McLennan miles in West direction from Moody (Town)



Give legal location with distances and directions from adjacent sections or survey lines.  
 Labor \_\_\_\_\_ League \_\_\_\_\_  
 Block \_\_\_\_\_ Survey \_\_\_\_\_  
 Abstract No. \_\_\_\_\_  
 (NW 1/4, NE 1/4, SW 1/4, SE 1/4) of Section \_\_\_\_\_

1) TYPE OF WORK (Check):  
 a) Well  Deepening  Plugging  
 b) PROPOSED USE (Check):  
 Domestic  Industrial  Municipal  Irrigation  Test Well  Other   
 c) TYPE OF WELL (Check):  
 Rotary  Driven  Dug  Cable  Jetted  Bored

2) WELL LOG:  
 Diameter of hole 11 in. Depth drilled 1160 ft. Depth of completed well 1406 ft. Date drilled Nov 27 1965  
 All measurements made from 0 ft. above ground level.

From (ft.)	To (ft.)	Description and color of formation material
0 - 140		Blue shale
10 - 275		Lime
11 - 1140		Bleached lime + shale
15 - 1200		1st TRINITY Sand
20 - 1290		Sandy shale
20 - 1300		Sand
30 - 1323		Shale
43 - 1406		Sandy sandy shale

9) CASING:  
 Type: Old  New  Steel  Plastic  Other   
 Cemented from 1160 ft. to 0 ft.  
 Diameter (inches) \_\_\_\_\_ Setting From (ft.) \_\_\_\_\_ To (ft.) \_\_\_\_\_ Gage \_\_\_\_\_  
9 2' above ground 1160-2016

10) SCREEN:  
 Type Steel  
 Perforated  Slotted   
 Diameter (inches) 4 1/2 Setting From (ft.) 1140 To (ft.) 1406 Slot Size 1/2 x 9"

COMPLETION (Check):  
 Straight wall  Gravel packed  Other   
 Under reamed  Open Hole  4 1/2" LIND  
 WATER LEVEL:  
 Static level 465 ft. below land surface Date 11-4-65  
 Artesian pressure \_\_\_\_\_ lbs. per square inch Date \_\_\_\_\_  
 Depth to pump bowls, cylinder, jet, etc., 575 ft. below land surface.

11) WELL TESTS:  
 Was a pump test made?  Yes  No If yes, by whom? McClinton  
 Yield: 160 gpm with 50 ft. drawdown after 5 hrs.  
 Bailor test \_\_\_\_\_ gpm with \_\_\_\_\_ ft. drawdown after \_\_\_\_\_ hrs.  
 Artesian flow \_\_\_\_\_ gpm  
 Temperature of water \_\_\_\_\_

12) WATER QUALITY:  
 Was a chemical analysis made? Yes  No   
 Did any strata contain undesirable water? Yes  No   
 Type of water? \_\_\_\_\_ depth of strata \_\_\_\_\_

I hereby certify that this well was drilled by me (or under my supervision) and that each and all of the statements herein are true to the best of my knowledge and belief.  
 NAME R.H. McCLINTON Water Well Drillers Registration No. 1276  
 (Type or Print)  
 ADDRESS RT 2 Box 196 Elkport Texas  
 (Street or RFD) (City) (State)  
 (Signed) R.H. McClinton (Water Well Driller)  
McClinton Drilling Co (Company Name)

Please attach electric log, chemical analysis, and other pertinent information, if available.

Additional instructions on reverse side.