

40-38-202

Send original copy by certified mail to the Texas Water Development Board P. O. Box 12386 Austin, Texas 78711

State of Texas WATER WELL REPORT

For TWDB use only Well No. 40-38-2A Located on map 1225 Received: 9/3/72

1) OWNER: Person having well drilled Harris Creek Country Estates Address 1401 Jefferson, Waco, Texas 76702 Landowner same Address same

2) LOCATION OF WELL: County McLennah 5 miles in E. direction from McGregor See Map North (Use reverse side if necessary)

3) TYPE OF WORK (Check): New Well X Deepening Reconditioning Plugging 4) PROPOSED USE (Check): Domestic Industrial Municipal X Irrigation Test Well Other 5) TYPE OF WELL (Check): Rotary X Driven Dug Cable Jetted Bored

6) WELL LOG: Diameter of hole 12 in. Depth drilled 1306 ft. Depth of completed well 1306 ft. Date drilled Nov. 8, 1972 All measurements made from 3 ft. above ground level.

Table with 3 columns: From (ft.), To (ft.), Description and color of formation material. Rows include Surface soil, Gravel, Lime, Broken lime with sand streaks, Broken sand, Sand, Broken sand, Lime and shale, Sandy shale, Red shale, Sand, Shale and lime.

9) CASING: Type: Old X New Steel Plastic Other Cemented from 0 ft. to 1306 ft. Diameter (inches) Setting From (ft.) To (ft.) Gage 12 3/4" O.D. 0 20 45# 8 5/8" O.D. 0 1306 28#

10) SCREEN: Type Perforated Slotted Diameter (inches) Setting From (ft.) To (ft.) Slot Size Casing gun perforated with 30 shots from 1048, 29 shots from 1074 to 1094, 40 shots from 1228 to 1248 and 13 shots from 1252 to 1258.

7) COMPLETION (Check): Straight wall Gravel packed Other Under reamed Open Hole

11) WELL TESTS: Was a pump test made? Yes X No If yes, by whom? Yield: gpm with ft. drawdown after hrs. Bailer test gpm with ft. drawdown after hrs. Artesian flow gpm Temperature of water

8) WATER LEVEL: Static level ft. below land surface Date Artesian pressure lbs. per square inch Date Depth to pump bowls, cylinder, jet, etc., ft. below land surface. Electric log, radioactivity log, pump test, chemical analysis enclosed.


12) WATER QUALITY: Was a chemical analysis made? Yes X No Did any strata contain undesirable water? Yes No X Type of water? depth of strata

I hereby certify that this well was drilled by me (or under my supervision) and that each and all of the statements herein are true to the best of my knowledge and belief. NAME J.L. Myers Company Water Well Drillers Registration No. 1227 ADDRESS 5306 Harry Hines Blvd. Dallas Texas 75235 (Signed) W.E. Ross (Water Well Driller) J.L. Myers Company (Company Name)

Please attach electric log, chemical analysis, and other pertinent information, if available.

*Additional instructions on reverse side.

FROM (ft)	TO (FT)	
0	4	surface soil
4	7	gravel
7	132	lime
132	1010	broken lime with sand streaks
1010	1017	broken sand
1017	1068	sand
1068	1099	broken sand
1099	1113	lime and shale
1113	1180	sandy shale
1180	1215	red shale
1215	1250	sand
1250	1306	shale and lime



40-38-202